

COUNTY OF FRESNO

ADDENDUM NUMBER: ONE (1)

RFQ NUMBER: 578-5215

RELOCATABLE OFFICE UNIT FOR HOUSEHOLD HAZARDOUS WASTE (HHW) FACILITY

October 14, 2013

PURCHASING USE

ssl

G:\PUBLIC\RFQ\578-5215 ADD 1.DOC

IMPORTANT: SUBMIT QUOTATION IN SEALED PACKAGE WITH QUOTATION NUMBER, CLOSING DATE AND BUYER'S NAME MARKED CLEARLY ON THE OUTSIDE TO:

COUNTY OF FRESNO, Purchasing
4525 EAST HAMILTON AVENUE, 2ND FLOOR
FRESNO, CA 93702-4599

CLOSING DATE OF BID WILL BE AT 2:00 P.M., ON OCTOBER 23, 2013.

QUOTES WILL BE CONSIDERED LATE WHEN THE OFFICIAL PURCHASING TIME CLOCK READS 2:00 P.M.

Quotes will be opened and publicly read at that time. All quotation information will be available for review after contract award.

Clarifications of specifications is to be directed to: **Brian D. Tamblin**, phone (559) 600-7110, e-mail CountyPurchasing@co.fresno.ca.us, fax (559) 600-7126.

NOTE THE ATTACHED ADDITIONS, DELETIONS AND/OR CHANGES TO THE REQUIREMENTS OF REQUEST FOR QUOTATION NUMBER: 578-5215 AND INCLUDE THEM IN YOUR RESPONSE. PLEASE SIGN AND RETURN THIS ADDENDUM WITH YOUR QUOTATION.

ACKNOWLEDGMENT OF ADDENDUM NUMBER ONE (1) TO RFQ 578-5215

COMPANY NAME: _____
(PRINT)

SIGNATURE: _____

NAME & TITLE: _____
(PRINT)

QUESTIONS & ANSWERS

Q1 Ref. page 16. Can you please provide additional detail for PVC flooring over cement-bonded floor, i.e. typical manufacturer, model & type of PVC and cement-bonded floor? OR alternatively will the following product be acceptable: BLT – Better Life Technology, G-Floor, 100% Solid Polyvinyl, Levant Pattern, 55 Mil (75 mil also available).

A1 G-Floor is used for automobile parking garages and the Levant Pattern is a stipple (leather) finish and appears to come in grey only. This flooring is acceptable in 75 mil.

Q2 Ref. page 16. It states that office unit shall be fully self-contained. As a clarification will the County be making an electrical connection to the Office Unit or will the electrical be running off of a generator?

A2 The County will provide electrical power to the office. The Office power connection must be located on the left end of the office as you're looking at the entry door.