

**COUNTY OF FRESNO**  
**ADDENDUM NUMBER: ONE (1)**  
**RFQ NUMBER: 680-5487**  
**INTRUSION ALARM INSTALLATION, MONITORING,**  
**MAINTENANCE AND REPAIR**

---

Issue Date: August 24, 2016

IMPORTANT: SUBMIT QUOTATION IN SEALED PACKAGE WITH QUOTATION NUMBER, CLOSING DATE AND BUYER'S NAME MARKED CLEARLY ON THE OUTSIDE TO:

COUNTY OF FRESNO, PURCHASING  
4525 EAST HAMILTON AVENUE, 2<sup>nd</sup> Floor  
FRESNO, CA 93702-4599

**CLOSING DATE OF QUOTATION WILL BE AT 2:00 P.M., ON SEPTEMBER 7, 2016.**

**QUOTATION WILL BE CONSIDERED LATE WHEN THE OFFICIAL PURCHASING TIME CLOCK READS 2:01 P.M.**

All quotation information will be available for review after contract award.

Questions must be submitted on the Bid Page at Public Purchase or contact **Bryan Hernandez** at (559) 600-7117.

**NOTE THE "FOLLOWING AND ATTACHED" ADDITIONS, DELETIONS AND/OR CHANGES TO THE REQUIREMENTS OF REQUEST FOR QUOTATION NUMBER: 680-5487 AND INCLUDE THEM IN YOUR RESPONSE. PLEASE SIGN IN BLUE INK AND RETURN THIS ADDENDUM WITH YOUR QUOTATION.**

- **Closing date has been extended to September 7, 2016 at 2:00 PM**
- **The attached Questions and Answers**
- **Attachment "A"**

**ACKNOWLEDGMENT OF ADDENDUM NUMBER One (1) TO RFQ 680-5487**

COMPANY NAME: \_\_\_\_\_ (PRINT)

SIGNATURE (In Blue Ink): \_\_\_\_\_

NAME & TITLE: \_\_\_\_\_ (PRINT)

Purchasing Use: BH:HM

ORG/Requisition: 31113301 / 3111602706

## QUESTIONS AND ANSWERS

**Q1. What was the method of entry into the building from the previous burglary?**

*A1. Back door.*

**Q2. Looking at the maps, which is the main office?**

*A2. Directed them to the map of the main building (refer to Exhibits A and B of the RFQ).*

**Q3. Is this the only location for the project?**

*A3. Yes.*

**Q4. Is this for service and monitoring?**

*A4. This quote is for equipment, installation, yearly maintenance and monitoring.*

**Q5. What is the length of the contract?**

*A5. 3 years with two (2) one (1) year renewals upon mutual written consent of all parties.*

**Q6. Is there a list of current equipment for the main office?**

*A6. Yes, listed on the map of the main building (refer to Exhibit A of the RFQ).*

**Q7. Does this cover the wiring?**

*A7. The bid is all work, including materials. Existing wiring is included.*

**Q8. Is the existing wiring already in conduit?**

*A8. There is existing conduit however there is no usable conduit to run additional wiring.*

**Q9. Does the contract go to the lowest bidder?**

*A9. Contract will be awarded to the lowest bid with quality of work to be considered.*

**Q10. Does the wiring need to be run in conduit?**

*A10. Yes, we would recommend using conduit due to possible rodents under the office that could damage any new wiring.*

**Q11. Is there existing conduit to run the wiring?**

*A11. There is no usable conduit to run additional wiring.*

**Q12. Are you upgrading the panel?**

*A12. RFQ states existing equipment will be used.*

**Q13. When will the job start?**

*A13. Upon execution of an agreement by both parties.*

**Q14. Can you provide the height of the "day room"? we are requesting measurements from Floor to Roof Beam.**

*A14. Approximately 25 feet.*

**Q15. Can you provide a picture of the alarm control panel with the panel door open?**

*A15. See Attachment A.*

## **ATTACHMENTS:**

### **A. Alarm Control Panel**

## Attachment “A”

