

# COUNTY OF FRESNO

## ADDENDUM NUMBER: ONE (1)

RFQ NUMBER: 895-5230

### FIRE SUPPRESSION WATER TANK

December 18, 2013

PURCHASING USE

[typist]

G:\PUBLIC\RFQ\895-5230 ADD 1.DOC

IMPORTANT: SUBMIT QUOTATION IN SEALED PACKAGE WITH QUOTATION NUMBER, CLOSING DATE AND BUYER'S NAME MARKED CLEARLY ON THE OUTSIDE TO:

COUNTY OF FRESNO, Purchasing  
4525 EAST HAMILTON AVENUE, 2<sup>ND</sup> FLOOR  
FRESNO, CA 93702-4599

**CLOSING DATE OF BID WILL BE AT 2:00 P.M., ON DECEMBER 27, 2013.**

**QUOTES WILL BE CONSIDERED LATE WHEN THE OFFICIAL PURCHASING TIME CLOCK READS 2:00 P.M.**

Quotes will be opened and publicly read at that time. All quotation information will be available for review after contract award.

Clarifications of specifications is to be directed to: **Caleb J. Brooks**, phone (559) 600-7110, e-mail [CountyPurchasing@co.fresno.ca.us](mailto:CountyPurchasing@co.fresno.ca.us), fax (559) 600-7126.

**NOTE THE FOLLOWING AND ATTACHED ADDITIONS, DELETIONS AND/OR CHANGES TO THE REQUIREMENTS OF REQUEST FOR QUOTATION NUMBER: 895-5230 AND INCLUDE THEM IN YOUR RESPONSE. PLEASE SIGN AND RETURN THIS ADDENDUM WITH YOUR QUOTATION.**

- **Please see Bidders questions and County answers on the next page. Such questions were submitted at the Bidders Conference December 16, 2013 and/or prior to the questions period cut-off December 18, 2013.**

#### **ACKNOWLEDGMENT OF ADDENDUM NUMBER ONE (1) TO RFQ 895-5230**

COMPANY NAME: \_\_\_\_\_  
(PRINT)

SIGNATURE: \_\_\_\_\_

NAME & TITLE: \_\_\_\_\_  
(PRINT)

## QUESTIONS AND ANSWERS

**Q1: Reference permits, we assume since you are already doing the foundation work, that permits are already taken care of and that we do not need to permit the tank?**

*A1: The tank design has to be reviewed and approved by Fresno Fire Department prior to manufacture.*

**Q2: For our tank, you are expecting for us to supply engineering for the tank. We need to know if you are also looking for the anchor bolts calculations or did the foundation engineer already provide that?**

*A2: The design and engineering for Anchoring of the tank has already been completed.*

**Q3: If we need to provide anchorage calculations, if awarded the project we will need to get the engineering details for the slab and a soils report. Can you supply that information?**

*A3: No. The slab has already been poured.*

**Q4: As per the conversation yesterday with Keynan, we are manufacturing the tank only, setting it and anchoring it to your existing slab, and Fresno county or others are doing all plumbing and/or other hook ups. Please confirm.**

*A4: Confirmed. Delivering and setting only.*

**Q5: Payment Terms: We would like to request 50% down payment with receipt of order and balance net 45 days from our completion on-site.**

*A5: The County will not offer a down payment. Reference "INVOICING" and "PAYMENT" terms on Page 5 of the original RFQ.*

**Q6: Bid opening is December 27th, how soon will the award be made, please list specific date?**

*A6: A specific date of award cannot be given. Reference "AWARD" terms on Page 3 of the original RFQ*

**Q7: In lieu of terms requested above, how soon could we expect a deposit?**

*A7: Reference "INVOICING" and "PAYMENT" terms on Page 5 of the original RFQ.*

**Q8: You are requesting Tank to be complete and installed by January 27<sup>th</sup>, 2014. Is this date negotiable? If yes, please describe.**

*A8: It is the County's expectation that the tank be delivered and set on site by that date.*

**ADDENDUM NO. ONE (1)**  
**REQUEST FOR QUOTATION NUMBER 895-5230**  
**December 18, 2013**

**Page 3**

**Q9:** You are requesting a ladder from ground to roof, but do not ask for a roof guard rail, do you need one?

*A9: Depends upon the height of the tank.*

**Q10:** Does the above bid require a CA contractors license?

*A10: No. The fire tank should be a finished product delivered set on site. The County's General Contractor will do the final plumbing needed.*