

COUNTY OF FRESNO

ADDENDUM NUMBER: ONE (1)

RFP NUMBER: 990-5203

SHERIFF SECURITY SYSTEM

September 16, 2013

PURCHASING USE

CJN

G:\PUBLIC\RFP\990-5203 ADD 1.DOC

IMPORTANT: SUBMIT PROPOSAL IN SEALED PACKAGE WITH PROPOSAL NUMBER, CLOSING DATE AND BUYER'S NAME MARKED CLEARLY ON THE OUTSIDE TO:

COUNTY OF FRESNO, Purchasing
4525 EAST HAMILTON AVENUE, 2nd Floor
FRESNO, CA 93702-4599

CLOSING DATE OF PROPOSAL WILL BE AT 2:00 P.M., ON SEPTEMBER 18, 2013.

PROPOSALS WILL BE CONSIDERED LATE WHEN THE OFFICIAL PURCHASING TIME CLOCK READS 2:00 P.M.

Proposals will be opened and publicly read at that time. All proposal information will be available for review after contract award.

Clarification of specifications is to be directed to: **Craig Nickel, phone (559) 600-7115,**
e-mail CountyPurchasing@co.fresno.ca.us, FAX (559) 600-7126.

NOTE THE FOLLOWING AND ATTACHED ADDITIONS, DELETIONS AND/OR CHANGES TO THE REQUIREMENTS OF REQUEST FOR PROPOSAL NUMBER: 990-5203 AND INCLUDE THEM IN YOUR RESPONSE. PLEASE SIGN AND RETURN THIS ADDENDUM WITH YOUR PROPOSAL.

INCLUDED IN THIS ADDENDUM:

- Questions/Comments submitted by a potential bidder.
- Response to Questions/Comments above.
- List of Work Orders for a one (1) year period (June 2012 thru July 2013).

ACKNOWLEDGMENT OF ADDENDUM NUMBER ONE (1) TO RFP 990-5203

COMPANY NAME: _____
(PRINT)

SIGNATURE: _____

NAME & TITLE: _____
(PRINT)

Questions/Comments submitted by a potential bidder.

Concerned how a CONTRACTOR can replace existing equipment, when parts aren't available.

Concerned how this relates to Page 23, second paragraph "The CONTRACTOR will not be held responsible for the cost associated with repair or replacement of items in the event of a catastrophic failure of the entire system.

In Response to Questions/Comments above:

Insert the following on Page 23, Scope of Work (before SPECIFIC REQUIREMENTS section):

In instances where replacement parts are no longer available, CONTRACTOR must make every effort to repair or replace the existing equipment to make it operable.

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

DATE	LOCATION	PROBLEM	SOLUTION
06/01/12	MJ-6 SEC	DEF SIDE SECURITY DOOR SWITCH IS INTERMITENT	REPLACE DOOR SWITCH
06/01/12	NAJ-4 POD D	DOOR FLASHING RED WHEN SECURE	CHECK REFER TO LOCKSMITH
06/04/12	MJ-6 INFIRM.	TUBE ST. #5, STUCK TUBE	REMOVE STUCK TUBE AND LOOSE MAIL
06/04/12	NAJ-3	SALLYPORT BY POD B, DIRTY SMOKE DET	CLEAN AND REPLACE SD
06/05/12	SAJ-BASEMENT	CAMERA FOR SLIDER BY BREAKROOM IS OUT	REPLACE CAMERA
06/05/12	MJ-6 SEC	ABC SIDE MICROPHONE IS NOT WORKING	C/O REPAIR MIC WIRING
06/07/12	SAJ-3, F-G	HALL DOORS FLASHING WHEN SECURE	CHECK REFER TO LOCKSMITH
06/08/12	SAJ-4 SEC	MAIN CALLUP MONITOR IS OUT	REPLACE MONITOR
06/11/12	SAJ-2 CENTRAL	CAMERA FOR COURT HOLDING HALL DOOR IS OUT	REPLACE CAMERA
06/11/12	SAJ-2 SEC	CAMERA FOR LAUNDRY DOOR WON'T CALLUP	REPROGRAM SWITCHER
06/11/12	MJ-2 CENTRAL	DOOR SWITCH FOR OFFICER ENTRY IS FALLING APART	REPLACE SWITCH
06/12/12	MJ ALL	TUBE SYSTEM IS NOT WORKING	CHECK AND RESET ALL STATIONS
06/12/12	SAJ-1 VISITING	1 PHONE HAS EXPOSED WIRES	REPAIR WIRING
06/13/12	MJ-TUNNEL	CAMERA FOR TUNNEL SECURITY HAS INTERFERENCE	REPLACE VIDEO AMP AND CAMERA
06/13/12	NAJ-3	TUBE STATION #40 WON'T SEND TUBES	RESET STATION
06/13/12	SAJ-1 M STREET	DOOR FOR INMATE VISIT AND BOND ROOMS WON'T SECURE	REPLACE SWITCH
06/15/12	MJ-4, F-4	INTERCOM LAMP NOT WORKING	RESEAT IC CARD
06/15/12	MJ-4, E-2	GREEN DOOR LAMP IS OUT	REPLACE LAMP
06/18/12	MJ-6, D-3	IC LAMP STAYS ON, WON'T RESET	REPLACE IC SWITCH
06/18/12	MJ-4, POD B	DAYROOM SPEAKER BROKE OFF WALL	REPLACE SPEAKER BRACKET
06/18/12	MJ-1 BOOKING	BOND ROOM #1 BROKEN HANDSET	REPLACE HANDSET
06/19/12	MJ-4 SECURITY	VIDEO SWITCHER IS LOCKED UP	REPLACE VIDEO DISTRIBUTION AMP
06/19/12	MJ-4 CLASSROOM	CAMERA VIEW IS FOGGED UP	REPLACE CAMERA
06/20/12	SAJ-1 ATTY INTER	WATER CAUSED SMOKE DET DAMAGE	REPLACE SD AND BASE
06/20/12	MJ-4, E-10	DOOR FLASHING RED WHEN SECURE	REPLACE DOOR CARD, REFER TO LOCKSMITH
06/20/12	ALL	CHANNEL 26 IS OUT	RESET MA TV SYSTEM, CHECK ALL CHANNELS
06/21/12	MJ-BASEMENT	CAMERA VIEWING TUNNEL SEC IS DISTORTED	REPAIR VIDEO FITTINGS IN TUNNEL SEC
06/21/12	MJ- BOOKING	BOND ROOM #3 BROKEN HANDSET	REPLACE HANDSET
06/21/12	MJ-1	RELEASE HALL CAMERA IS OUT OF ADJUSTMENT	ADJUST CAMERA
06/22/12	MJ-2 CENTRAL	MONITOR #9 IS OUT	REPLACE MONITOR
06/22/12	SAJ-3	IC IS BLEEDING OVER, LOW VOLUME	RESET SYSTEM, REPLACE VOLUME CONTROL
06/23/12	MJ-1	OFFICER ENTRY DOOR, BROKEN TOGGLE	C/O REPLACE DOOR SWITCH
06/24/12	MJ-2 ELEV #4	VESTIBULE DOOR UNLOCKING BY ITSELF	C/O REPLACE DOOR SWITCH
06/25/12	MJ-1	SEVERAL CAMERAS ARE OUT	REPLACE DISTRIBUTION AMP

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

06/26/12	MJ-2 CENTRAL	BROKEN TOGGLE FOR ACCOUNTING VESTIBULE IC	REPLACE TOGGLE
06/27/12	SAJ-3, F-G	PLUMBING CHASE DOOR SHOWS RED	RESET ALARM AT PANNEL
06/27/12	SAJ-1 VISITING	SEVERAL PHONES ARE OUT	REPLACE 4 HANDSETS, REPAIR 3, CHECK ALL
06/28/12	MJ-3, D-6	BROKEN IC SWITCH	REPLACE TOGGLE
06/28/12	MJ-3, F-14	BROKEN IC SWITCH	REPLACE TOGGLE
06/29/12	MJ-1	LOADING DOCK HALL CAMERA IS OUT	REPLACE CAMERA
06/29/12	MJ-4, A-5	IC LAMP IS OUT	REPLACE LAMP
06/29/12	NAJ-3 VISITING	#4 PHONE ON INMATE SIDE EXPOSED WIRES	REPLACE HANDSET
06/29/12	MJ-4, C-12	BROKEN DOOR SWITCH	REPLACE TOGGLE
07/02/12	MJ-2 BRIEFING	DOOR TO C-1 BOUNCES OPEN	CHECK, REFER TO MAINTENANCE
07/02/12	SAJ-1 BOND RM-A	INMATE SIDE CAN'T HEAR	MICROPHONE IS ON ORDER
07/03/12	MJ-2 ELEV #2	VESTIBULE IC NOT WORKING	CHECK IC BUTTON, SWITCH AND CARD
07/03/12	MJ-2 CENTRAL	CAMERA FOR 1ST FLOOR ELEV. #2 VESTIBULE IS DISTORTED	LOCATE AND REPAIR VIDEO FITTING
07/03/12	MJ-1 BOOKING	BOND ROOM #3 PHONE HAS EXPOSED WIRES	REPAIR HANDSET WIRING
07/05/12	MJ-2 ELEV. #4	VESTIBULE TO STAIRWELL IC IS NOT WORKING	REPLACE IC SWITCH
07/06/12	SAJ-BASEMENT	FIRE ALARM WON'T RESET	REPLACE DIRTY SD ABOVE DRYERS
07/06/12	MJ-4 C-2	BROKEN TOGGLE	REPLACE TOGGLE
07/09/12	SAJ-4	LIGHTS IN D PANNEL SHOW UNSECURE	CHECK, REFER TO LOCKSMITH
07/10/12	SAJ-2, G-4	TV CABLE FITTING IS LOOSE	REPLACE FITTING
07/10/12	NAJ-1	COURT HOLDING MINICOM WON'T RESET	REPLACE BOX
07/10/12	MJ-2 CENTRAL	BROKEN TOGGLE FOR ACCOUNTING VESTIBULE	C/O REPLACE TOGGLE
07/11/12	MJ-YARD	ALL DOORS AND LAMPS ARE DEAD	REPLACE MAIN FUSE AND 1 DOOR CARD CHECK ALL
07/11/12	NAJ-1 DEPT 96	PANIC ALARM WON'T RESET	RESET BUTTON AT JUDGES DESK
07/12/12	NAJ-1 CENTRAL	ELEV. IC PTT BUTTON IS BROKEN	REPLACE BUTTON
07/12/12	MJ-3 ELEV. #3	DOOR SHOWS RED ALL THE TIME	REPLACE DOOR CARD, REFER TO LOCKSMITH
07/12/12	MJ-4, C-9	DOOR LOCKS BY ITSELF	REPLACE DOOR SWITCH
07/13/12	SHERIFF DISP	HALON SYSTEM TROUBLE, BUILDING ALARM ACTIVATION	UNKNOWN CAUSE
07/13/12	MJ-2 CENTRAL	DOOR SWITCH FOR BASEMENT TUNNEL X-OVER IS STUCK IN UNLOCK	REPLACE DOOR SWITCH
07/15/12	MJ-6	WATER FLOW FIRE ALARM WON'T RESET	C/O RESET FLOW SWITCH AND FIRE ALARM
07/17/12	SAJ-1 BOND RM-A	IC NOT WORKING	REPLACE MICROPHONE ON VISITOR SIDE
07/17/12	MJ-3 SECURITY	TUBE STATION COVER CAME OPEN	LOCK COVER
07/17/12	MJ-5, FF-5	IC WON'T CALL IN	REPLACE IC SWITCH
07/17/12	MJ-6, DEF SIDE	MICROPHONE NOT WORKING	REPAIR WIRING
07/17/12	MJ-6, F-16	BROKEN TOGGLE FOR DOOR	REPLACE TOGGLE
07/18/12	MJ-3, E1	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
07/18/12	MJ-5	FIRE ALARM IN SECURITY STATION AREA	CHECK ALL SD IN AREA OK

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

07/18/12	MJ ALL	TUBE SYSTEM WEAK PRESSURE	REPLACE 2 MOTORS
07/19/12	MJ-3 ELEV #2	DOOR SHOW RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
07/19/12	NAJ-BASEMENT	TUBE STATION #21 IS LEAKING AIR	REMOVE WATER CLEAN AND TEST
07/19/12	MJ-6 POD F	REMOVE POD AND CELL DOOR INTERLOCK	POD DOORS A,C, AND D ARE INTERLOCKED
07/20/12	MJ-6, D-13	DOOR WON'T UNLOCK FROM CONSOLE	REPLACE DOOR SWITCH
07/20/12	MJ-6, D-13	DOOR FLASHING RED WHEN SECURE	REFER TO LOCKSMITH
07/21/12	MJ-6, F-8	DOOR WON'T UNLOCK FROM CONSOLE	C/O REPLACE DOOR CARD, REFER TO LOCKSMITH
07/23/12	MJ-6	FIRE ALARM ZONE 23, VISITING, WATER LEAK	BYPASS ZONE RESET ALARM
07/24/12	MJ-1 LOBBY	INMATE RELEASE DOOR OUTER UNLOCKING BY ITSELF	C/O REPLACE DOOR SWITCH
07/25/12	MJ-1 CLOTHING	DOOR SWITCH IS MISSING COVER	REPLACE COVER
07/25/12	NAJ-ALL	TUBE SYSTEM WEAK VACUUM	REMOVE LOOSE MAIL FROM SYSTEM
07/26/12	MJ-1 BOOKING	SAFETY CELL #4 DAMAGED SMOKE DET	REPLACE SMOKE DET AND COVER
07/26/12	MJ-3, C-2	DOOR FLASHING RED WHEN SECURE	REPLACE DOOR CARD, REFER TO LOCKSMITH
07/27/12	SAJ-2 CENTRAL	ELEV IC MIC IS NOT WORKING	REPAIR MIC WIRING
07/27/12	SAJ-3, G-1	IC, CAN'T HEAR INMATES	RESET IC AND TEST OK
07/30/12	SAJ-4-E	SEVERAL LAMPS ARE OUT IN CONTROL PANEL FOR TANK	CHECK, REFER TO ELECTRICIAN
08/02/12	MJ-3 ELEV #1	DOOR SHOWS RED WHEN SECURE	SHAKE DOOR GOES RED-GREEN REFER TO LOCKSMITH
08/03/12	MJ-2 CENTRAL	ADMIN DOOR WON'T UNLOCK	REPLACE DOOR SWITCH
08/03/12	MJ YARD	DOOR R007A RED WHEN SECURE	CHECKED NO PROBLEM FOUND
08/03/12	MJ-4-C-9	DOOR LOCKS BY ITSELF	REPLACE DOOR CARD
08/06/12	MJ-2 CENTRAL	DOOR SWITCH FOR INFIRMARY WON'T UNLOCK	REPLACE SWITCH
08/06/12	MJ-1 BOOKING	BOND ROOM #1 BROKEN PHONE	REPLACE HANDSET REPAIR BENT HOOK SWITCH
08/06/12	NAJ-5	MECHANICAL ROOM SOUTH-EAST, DIRTY SMOKE DETECTOR	CLEAN SMOKE DET.
08/07/12	SAJ-1	FIRE ALARM TROUBLE, AIR HANDLER #1 NO ANSWER	TIGHTEN WIRING ON AH-1 SMOKE DET.
08/07/12	MJ-5 FF HALL	DOOR A SWITCH IS BROKEN	REPLACE TOGGLE
08/09/12	MJ-YARD	MINI COM BOX WON'T CANCEL	REPLACE BOX
08/09/12	MJ-1 BOOKING	BOND ROOM #3 PHONE NOT WORKING	REPLACE HANDSET
08/09/12	NAJ-4 SEC	ABC SIDE MONITOR IS OUT	REPLACE MONITOR
08/10/12	MJ-3 VISITING	#1 PHONE ON INMATE SIDE HAS EXPOSED WIRES	REPLACE HANDSET
08/10/12	MJ-4 SEC	ABC SIDE LAMP TEST IS NOT WORKING	LOCATE AND REPLACE FUSE
08/10/12	MJ-6-B-16	DOOR FLACHES RED WHEN SECURE	CHECK REFER TO LOCKSMITH
08/11/12	NAJ-5	STAFF RESTROOM HEAT DET KEEPS GOING INTO ALARM	C/O REPLACE HEAT DET

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

08/13/12	MJ-4-A10	INMATE BROKE LOCK, INTERLOCK WON'T ALLOW OTHER DOORS TO UNLOCK	REMOVE INTERLOCK FROM A-10 ONLY
08/13/12	MJ-BASEMENT	MINI COM BOX CUTS OUT SOMETIMES	REPLACE IC BOX
08/13/12	MJ-YARD	ELEV #3 DOOR SHOWS RED WHEN SECURE	CHECK NO PROBLEM FOUND
08/14/12	MJ-2 CENTRAL	DOOR 2007, ELEV #4 RELOCKS BY ITSELF	REPLACE DOOR CARD
08/14/12	SAJ-2	RADIO VOLUME IS TOO LOW	CLEAN VOLUME CONTROLS AT RADIO CONSOLE
08/14/12	MJ-1 BOOKING	VEHICLE SALLYPORT EXIT DETECTOR NOT WORKING	REPLACE SIGNAL TUBING
08/14/12	MJ-4, A-10		REINSTALL DOOR INTERLOCK
08/16/12	MJ-3 SECURITY	BROKEN TOGGLE FOR POD A INTERCOM	REPLACE TOGGLE
08/16/12	MJ-CENTRAL	IC LAMP FOR ACCOUNTING INNER WON'T LIGHT UP	REPLACE LAMP
08/17/12	SAJ-3 SECURITY	INMATES CAN'T HEAR IN G POD	CHECK FOR BLEED OVER TEST OK
08/20/12	SAJ-4, E-6	INTERCOM BUTTON NOT WORKING	REPAIR LOOSE BUTTON
08/20/12	MJ-4, SECURITY	ELEV. #1 IC WON'T CALL IN	REPLACE IC SWITCH
08/20/12	NAJ-3, POD D	PLUMBING CHASE, DIRTY SMOKE DET	REPLACE WET SMOKE DET
08/20/12	NAJ-3	SALLYPORT BY POD E, DIRTY SMOKE DET	REPLACE DIRTY SMOKE DET
08/23/12	NAJ-4 POD A	TV SHUTOFF BUTTON NOT WORKING	CHECK, NO PROBLEM FOUND
08/23/12	NAJ-3, POD D	PLUMBING CHASE FIRE ALARM, WATER LEAK	REMOVE WET SMOKE DET
08/24/12	NAJ-3, POD D	PLUMBING CHASE	REPLACE SMOKE DET
08/27/12	NAJ-4	TUBE STATION #42, STUCK TUBE	REMOVE TUBE, REPAIR STATION
08/27/12	SAJ-4	CAMERA FOR A,F POD HALL IS OUT	REPLACE CAMERA
08/28/12	MJ-BASEMENT	ELEV. #3 VESTIBULE DOOR WON'T OPEN	C/O CHECK DOOR CARD, SWITCH AND FUSE REFER TO LOCKSMITH
08/29/12	MJ-BASEMENT	ELEV. #3 IC BROKEN TOGGLE	REPLACE TOGGLE
08/29/12	MJ-1 LOBBY	ELEV. #4 VESTIBULE DOOR SWITCH B NOT WORKING	REPLACE SWITCH
08/29/12	SAJ-4, E-7	IC WON'T CALL IN	REPLACE CALL IN SWITCH
08/30/12	MJ-2 SECURITY	ELEV. #3 IC NOT WORKING	REPLACE IC CARD
08/30/12	MJ-2 CENTRAL	DOOR SWITCH FOR ADMIN-BRIEFING UNLOCKS IN NEUTRAL	REPLACE DOOR SWITCH
08/30/12	SAJ-1 VISITING	SEVERAL PHONES NOT WORKING, EXPOSED WIRES	REPLACE 3 HANDSETS, REPAIR 2
08/30/12	NAJ-3 SECURITY	ABC CONSOLE SPEAKER HAS STATIC	REPLACE SPEAKER
09/04/12	SAJ-2 SECURITY	IC VOLUME KNOB IS LOOSE, CHECK AUDIO	TIGHTEN KNOB, CHECK AUDIO
09/04/12	MJ-1 LOBBY	TUBE STUCK IN STATION #19	REMOVE TUBE, REPAIR STATION
09/04/12	NAJ-5	DEF IC IS NOT CLEAR	REPLACE MICROPHONE
09/04/12	MJ-6, F-8	DOOR FLASHING RED WHEN SECURE	REPLACE DOOR CARD, REFER TO LOCKSMITH
09/05/12	MJ-2	TUBE SYSTEM, DIVERTER #9 DIRTY OPTIC	CLEAN OPTIC
09/05/12	MJ-1, SECURITY	TUBE STUCK IN STATION #17, BROKEN LOADER	REPLACE FUSE, REMOVE STUCK TUBE

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

09/05/12	SAJ-3, G-4	POOR TV RECEPTION	REPLACE F FITTING ON WALL
09/06/12	MJ-BASEMENT	BROKEN TOGGLE FOR DOOR TO SAJ	REPLACE TOGGLE
09/06/12	MJ-6, POD F	INTERLOCK ALL CELL DOORS	
09/06/12	MJ-6	INTERLOCK ALL POD DOORS	
09/07/12	SAJ-2, POD D	INTERCOM RESET NOT WORKING	REPLACE IC RESET BUTTON
09/07/12	SAJ-2, CENTRAL	MINICOM MAKING FEEDBACK NOISE	REPLACE BOX, CABLE, ADJUST GAIN
09/08/12	MJ-2, CENTRAL	SWITCH FOR OFFICER ENTRY INNER UNLOCKS BY ITSELF	C/O REPLACE SWITCH
09/10/12	NAJ-5	DIRTY SMOKE DET MECHANICAL ROOM CENTER	REPLACE SMOKE DET
09/12/12	NAJ-BASEMENT	TUBE SYSTEM AIR COMPRESSOR DRIVE BELT FAILED	REPLACE DRIVE BELT
09/12/12	NAJ-3	METAL DET GOING OFF FOR NO REASON	NEW INMATE JUMPSUITS HAVE LARGER FASTENERS
09/13/12	NAJ-5	DIRTY SMOKE DET MECHANICAL ROOM S-E	LOWER SENSITIVITY 10%
09/13/12	MJ-2 CENTRAL	TUBE SYSTEM ZONE 2 IN ALARM	REPLACE SMOKE DET
09/13/12	MJ-2 CENTRAL	IC SWITCH FOR INFIRMARY OUTER DOOR IS FALLING APART	RESET TEST OK
09/13/12	MJ-2 CENTRAL	TUBE STATION #45 HAS BROKEN SLIDE GATE	REPLACE IC SWITCH
09/14/12	MJ-5-A-6,7	ABLE TO OPEN BOTH DOORS AT THE SAME TIME	REPAIR SLIDE GATE
09/17/12	SAJ-1 BOND RM B	BROKEN PHONE, INMATE SIDE	REPAIR WIRING ON INTERLOCK, TEST OK
09/17/12	SAJ-3 SEC	INMATES CAN'T HEAR IC	REPLACE HANDSET
09/18/12	SAJ-3	CAMERA IN A POD VESTIBULE IS OUT	CHECK MICROPHONE, TIGHTEN WIRES, TEST OK
09/18/12	NAJ-3	CAMERA VIEWING N-W STAIRWELL IS FALLING OFF MOUNT	REPLACE CAMERA
09/19/12	SAJ-3	CAMERA FOR B POD HALL IS OUT	SECURE CAMERA
09/19/12	SAJ-3	CAMERA FOR A POD HALL IS OUT	REPLACE CAMERA
09/19/12	MJ-BASEMENT	MINICOM NOT WORKING PROPERLY	REPAIR WIRING AT SWITCHER
09/24/12	MJ-2 CENTRAL	BROKEN TOGGLE FOR OFFICER ENTRY INNER DOOR	REPLACE IC BOX
09/24/12	NAJ-3	DEF CONSOLE MONITOR IS OUT	REPLACE TOGGLE
09/24/12	SAJ-3	IC BOX WON'T WORK HANDS FREE	REPROGRAM VIDEO SWITCHER
09/24/12	MJ-1 LOBBY	TUBE SYSTEM NOT WORKING	CHECK BOX NO PROBLEM FOUND
09/25/12	MJ TUBE SYSTEM	INTERMITTENT PRESSURE OPERATION	REMOVE STUCK TUBE FROM DIVERTER # 15, REPLACE 1 VACUUM MOTOR
09/25/12	ALL	MATV CHANNEL 21 HAS NO AUDIO	REPLACE 2 MOTOR CONTROL CONTACTORS
09/26/12	MJ-3-D, CELL 3-4	PLUMB CHASE, WATER LEAK CAUSED FIRE ALARM	RESET DEMODULATOR FOR CHANNEL 21
09/26/12	NAJ-3	DIRTY SMOKE DET MECHANICAL ROOM CENTER	LEAK REPAIRED BY BUILDING MAINTENANCE REPLACE SMOKE DET
09/27/12	SAJ-1,2,3,4		REPLACE SMOKE DET
09/28/12	MJ-1 BOOKING	PRE RELEASE B WON'T OPEN WITH KEY	REPLACE BATTERIES FOR CONTROL CONSOLES
			REPLACE DOOR CARD, REFER TO LOCKSMITH

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

09/28/12	SAJ-2-D-12	DIRTY DUCT SMOKE DET	CLEAN DUCT DET, SYSTEM NORMAL
09/28/12	MJ-1 BOOKING	CAMERA FOR VEHICLE SALLYPORT ENTRY DISTORTS WHEN PANNED	REPLACE CAMERA
10/1/2012	NAJ-1 CENTRAL	ELEV #3 IC BROKEN TOGGLE	REPLACE TOGGLE
10/1/2012	NAJ-5	DEF MONITOR B NOT WORKING	CHANGE MONITOR TO VIDEO 1, REPROGRAM SWITCHER
10/3/2012	MJ-1, LOBBY	RELEASE INNER DOOR SWITCH UNLOCKS IN NEUTRAL	REPLACE SWITCH
10/3/2012	NAJ TUBE	AIR SHIFTER SEAL IS LEAKING	REPLACE AIR SHIFTER SEALS
10/4/2012	MJ-1, BOOKING	DVR IS NOT RECORDING AUDIO	AUDIO PREAMP IS UNPLUGED, CONNECT, ADJUST AND TEST
10/5/2012	MJ-3-F-12	IC WON'T CALL IN	REPLACE IC SWITCH, TEST OK
10/5/2012	NAJ-1 CRT HOLD	PANIC ALARM ACTIVATED WON'T RESET	RESET BUTTON, RESET PANEL
10/5/2012	NAJ-5	POD F DOOR WON'T RELOCK	REPLACE DOOR SWITCH IN CONSOLE
10/8/2012	MJ-3 POD A	IC FROM OTHER PODS BLEED OVER	ADJUST IC AMP
10/8/2012	MJ-3-F-3	DOOR SHOWS RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
10/8/2012	MJ-3-D-3	DOOR SHOWS RED WHEN SECURE	CHECK, NO PROBLEM FOUND
10/9/2012	MJ-6 POD A	MEZZ LEVEL STAIRWELL DOOR RED BUT SECURE	CHECK, LOCK STICKS. REFER TO LOCKSMITH
10/9/2012	MJ-YARD	ELEV. #1 VEST DOOR RED WHEN SECURE	CHECK, NO PROBLEM FOUND
10/9/2012	MJ-YARD	SOUTH ENTRY BY ELEV. #1 RED WHEN SECURE	CHECK, LOCK STICKS. REFER TO LOCKSMITH
10/10/2012	MJ-1 BOOKING	TUBE STATION #20 HAS WEAK VACUUM	REPAIR AIR LEAK AT DIVERTER #19
10/12/2012	MJ-2 CENTRAL	BASEMENT STAFF DOOR TO ELEV. #1 VEST, IC LAMP NOT WORKING	REPAIR BROKEN WIRE ON IC INTERFACE CARD
10/12/2012	AJ-1 VISITING	SEVERAL PHONES HAVE BROKEN WIRES	REPAIR 3, REPLACE 2 HANDSETS
10/12/2012	MJ-1 LOBBY	METAL DET GOES OFF FOR NO REASON	CLEAN, ADJUST AND TEST OK
10/12/2012	MJ-1 BOOKING	BOND ROOM #3 BROKEN PHONE	REPLACE HANDSET, REPAIR HOOK SWITCH
10/15/2012	MJ-3	BROKEN TOGGLE FOR NORTH SALLYPORT	REPLACE TOGGLE
10/15/2012	MJ-1 BOOKING	OFFICER ENTRY DOOR SWITCH NOT WORKING	REPLACE SWITCH
10/15/2012	NAJ-1 CENTRAL	MONITOR FOR COURT HALLWAY IS GOING OUT	REPLACE MONITOR
10/15/2012	MJ-5, E-2	BROKEN TOGGLE FOR DOOR SWITCH	C/O REPLACE IC TOGGLE SWITCH
10/16/2012	NAJ-3	STAFF RESTROOM HEAT DET IN TROUBLE	REPLACE HEAT DET, BASE AND RESTART PANEL
10/16/2012	AJ-2 SEC	IC FOR LAUNDRY WINT CALLUP CAMERAS	REPROGRAM VIDEO SWITCHER
10/16/2012	MJ-1 BOOKING	MALE INTAKE DOOR SWITCH IS INTERMITTENT	REPLACE DOOR SWITCH
10/16/2012	NAJ-1 CENTRAL	DOOR MONITOR TROUBLE, CARD 22 FAILED	REPLACE SIMPLEX IO #22
10/18/2012	AJ-4 POD A	DAY ROOM IC CALLIN WON'T RESET	WATER LEAK CAUSED PROBLEM, WATER HAS DRIED OUT AND SYSTEM IS OPERATIONAL
10/18/2012	MJ-2 CENTRAL	OFFICER ENTRY OUTER DOOR WON'T UNLOCK FROM CONSOLE	C/O REPLACE DOOR SWITCH
10/19/2012	AJ-3 POD A	VESTIBULE CAMERA IS OUT	REPLACE BNC FITTING

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

10/19/2012	MJ-4-C-12	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
10/22/2012	MJ-2 CENTRAL	BRIEFING DOOR, INFIRMARY SIDE WON'T SECURE	REPLACE DOOR SWITCH AND DOOR CARD
10/22/2012	MJ-1 BOOKING	BOND ROOM #1 PHONE NOT WORKING	REPAIR HOOK SWITCH
10/23/2012	MJ-3-FF-8	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH FOR DPS ADJUSTMENT
10/23/2012	NAJ-1 CENTRAL	MONITOR FOR 2ND FLOOR CLASSROOM IS OUT	REPLACE MONITOR
10/24/2012	MJ-YARD	CENTER YARD DOOR SHOWS RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
10/25/2012	MJ-1	ELEV. #3 DOOR IS RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
10/25/2012	MJ-1 BOOKING	OFFICER ENTRY SHOWS RED WHEN SECURE SOMETIMES	CHECK, REFER TO ENGINEER
10/25/2012	MJ-2 CENTRAL	INFIRMARY SIDE DOOR IC DOESN'T LIGHT UP SOMETIMES	RESEAT IC INTERFACE CARD
10/25/2012	MJ-2 CENTRAL	ELEV. #4 VESTIBULE DOOR WON'T STAY UNLOCKED	REPLACE DOOR SWITCH
10/26/2012	MJ	TUBE SYSTEM WEAK PRESSURE	REPLACE 1 PRESSURE MOTOR, 1 FUSE
10/26/2012	MJ-3	CONSOLE ABC IC BLEEDS OVER	ADJUST IC AMP ADD GROUND WIRE TO SHIELDING
10/29/2012	MJ-4	POD D DOOR SHOWS RED WHEN SECURE	CHECK AND REFER TO LOCKSMITH
10/30/2012	MJ- BASEMENT	MINICOM WON'T CALLOUT	REPLACE BOX
10/31/2012	MJ-5, F-14	IC SPEAKER VANDALIZED, COMPLETELY COVERED WITH A STICKY SUBSTANCE	CLEAN AND TEST
11/1/2012	MJ-2 CENTRAL	BROKEN TOGGLE FOR ELEV. #3 IC	REPLACE TOGGLE
11/1/2012	MJ-1	VEHICLE SALLYPORT FIXED CAMERA HAS DISTORTED IMAGE	SECURE BNC FITTINGS AT VIDEO AMP
11/2/2012	SAJ-3	CAMERA FOR POD A VESTIBULE IS OUT	CHECK BNC CONNECTION, AND SWITCHER OK
11/5/2012	ALL	RESET ALL CLOCKS	
11/8/2012	MJ-5, F-11	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
11/8/2012	MJ-6, E-5-6	FIRE ALARM, WATER LEAK IN PLUMBING CHASE	BYPASS SMOKE DET, RESET ALARM
11/9/2012	MJ-3, B-5	DOOR SHOWS RED WHEN SECURE	REMOVE PAPER FROM STRIKE PLATE
11/9/2012	MJ-3, FF-8	DOOR FLASHES RED WHEN SECURE	PREVIOUSLY CHECKED 10-28 REFER TO LOCKSMITH
11/9/2012	MJ-2 CENTRAL	MINI COM NOT WORKING	REPLACE IC BOX
11/10/2012	MJ-2 CENTRAL	BROKEN TOGGLE FOR BACK DOOR INNER	CALL OUT REPLACE TOGGLE
11/13/2012	MJ-2 INFIRMARY	SEC CAMERA FOR C-2 IS OUT	REMOVE PAPER FROM CAMERA HOUSING
11/13/2012	MJ-2 SECURITY	TUBE STATION #11 HAS STUCK TUBE	REMOVE TUBE, REPAIR STATION
11/13/2012	MJ-1 BOOKING	DOOR SWITCH FOR MALE INTAKE NOT WORKING	REPLACE SWITCH
11/15/2012	MJ-3 ELEV. #2	DOOR SHOWS RED WHEN SECURE	REPLACE DOOR CARD, REFER TO LOCKSMITH
11/16/2012	SAJ-1 VISITING	SEVERAL PHONES ARE DAMAGED	REPLACE 1 HANDSET, REPAIR 2
11/20/2012	NAJ-4 POD C	TOILET HEAT DET IN ALARM	REPLACE BASE AND HEAD, INMATES THREW WATER ON DEVICE

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

11/20/2012	MJ-2 CENTRAL	SW SYAIRWELL DOOR LIGHT IS OUT	REPLACE LAMP
11/20/2012	MJ-3, FF-8	DOOR LIGHT FLASHING RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
11/21/2012	MJ-4-E	WILL SHOW RED WHEN SECURE	REPLACE DOOR CARD AND SWITCH, SEEMS TO BE WORKING NOW
11/21/2012	NAJ-5-F	TOILET HEAT DET IN ALARM	RESET ALARM
11/26/2012	SAJ-1 VISITING	MALE SIDE VISITING SLIDER SHOWS NOT SECURE	REPLACE LAMP IN SWITCH
11/26/2012	NAJ-5 SECURITY	IC BOX IS NOT WORKING	REPLACE BOX
11/26/2012	MJ-4-E	POD DOOR SHOWS RED WHEN SECURE	CHECK DOOR, REFER TO LOCKSMITH
11/26/2012	MJ-2	INFIRMARY SIDE BRIEFING DOOR LOCK GOES RED TO GREEN	REFER TO LOCKSMITH
11/27/2012	SAJ-2 SEC	9 INCH BLACK-WHITE MONITOR IS OUT	REPLACE MONITOR
11/28/2012	MJ-5	BROKEN TOGGLE FOR SECURITY DOOR	REPLACE TOGGLE
11/28/2012	MJ-5	BROKEN TOGGLE FOR ELEV. #1 IC	REPLACE TOGGLE
11/28/2012	MJ ALL VISITING	SEVERAL PHONES ARE BROKEN	REPAIR 2, REPLACE 2 HANDSETS
11/28/2012	MJ-3, E-9	DOOR LOCKS BY ITSELF	REPLACE DOOR SWITCH
		FIRE ALARM TROUBLE PULL STATION BY SEC DOOR	
	NAJ-5	NO ANSWER	REPLACE PULL STATION
11/29/2012	MJ-4, F-16	UNLOCK TIMMER IS TOO LONG	REPLACE DOOR CARD
11/30/2012	MJ-2 CENTRAL	BROKEN TOGGLE FOR INFIRMARY SIDE BRIEFING DOOR	REPLACE TOGGLE
12/3/2012	MJ-6	ABC SIDE MICROPHONE IS NOT WORKING	REPAIR MICROPHONE
12/3/2012	MJ-6, C-12	INTERCOM HAS NO AUDIO	REPAIR WIRING ON IC INTERFACE CARD
12/3/2012	SAJ-2 SECURITY	LAUNDRY DOOR CAMERA IS NOT CALLING UP	REPROGRAM VIDEO SWITCHER
12/3/2012	MJ-3, POD D	DOOR SHOWS RED WHEN SECURE	REPLACE DOOR CARD, LOCK MAYBE STICKING, REFER TO LOCKSMITH
12/4/2012	MJ-2 CENTRAL	MONITOR #9 IS OUT	REPAIR MONITOR
12/5/2012	MJ-2 CENTRAL	OFFICER ENTRY DOOR SWITCH UNLOCKS IN NEUTRAL	REPLACE DOOR SWITCH
12/7/2012	NAJ-1 CENTRAL	BROKEN TOGGLE FOR ELEV #1 IC	REPLACE TOGGLE
12/7/2012	SAJ-2 SECURITY	IC FOR G HAS NO AUDIO	RESET SYSTEM AND TEST OK
12/10/2012	MJ-6-A-7	IC LAMP NOT WORKING	REPLACE LAMP TEST
12/11/2012	NAJ-5 VISITING	PHONE #3 NOT WORKING	REPLACE HANDSET ON PUBLIC SIDE
12/11/2012	MJ-1 LOBBY	MONITOR FOR BOND ROOM IS JUMPING	RESET SWITCHER
12/12/2012	SAJ-1 M ST	DOOR SWITCH FOR VISITING IS NOT SHOWING GREEN	REPLACE LAMP
12/12/2012	SAJ-1 M ST	MONITOR WON'T TURN ON SOMETIMES	REPLACE MONITOR
12/12/2012	MJ-5	ISO B, BROKEN TOGGLE	REPLACE TOGGLE
12/12/2012	SAJ-2 CENRTAL	CAMERA FOR B-1 STAIRS IS OUT	REPLACE CAMERA

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

12/13/2012	MJ-2 CENTRAL	EAST STAIRWELL DOOR 4008 SHOWS RED WHEN SECURE	REPLACE DOOR CARD, REFER TO LOCKSMITH
12/13/2012	NAJ-1 CENTRAL	TUBE DIVERTER #21 HAS AIR LEAK	REPLACE AIR CYLINDERS
12/13/2012	MJ-2 CENTRAL	INFIRMARY DOOR BY ELEV #4 UNLOCKS BY ITSELF	REPLACE DOOR CARD AND SWITCH
12/14/2012	MJ-2 CENTRAL	DOOR IC MICROPHONE IS NOT WORKING	REPAIR WIRING
12/14/2012	NAJ-1 CENTRAL	ELEV #4 CAMERA IS OUT	RESET POWER FOR CAMERA
12/14/2012	NAJ-1 CENTRAL	FIRE ALARM TROUBLE, 4TH UNDER SEC MISSING HEAD	REPLACE SD HEAD
12/17/2012	MJ-5, FF-6	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
12/18/2012	SAJ-4 SEC	MASTER UNLOCK BUTTON NOT WORKING	REPLACE BUTTON
12/19/2012	MJ-6-B-12	DOOR SHOWS RED WHEN SECURE	CHECK LOCK, IT'S BROKEN REFER TO LOCKSMITH
12/20/2012	MJ-3-E-1	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
12/21/2012	MJ-1 LOBBY	TUBE STUCK	REMOVE TUBE, REPLACE LOADER MOTOR
12/21/2012	SAJ-3 SEC	MONITOR #5 IS OUT	REPLACE MONITOR
12/21/2012	SAJ-3 SEC	CAMERA FOR F-G STAIRWELL IS OUT	REPLACE CAMERA
12/21/2012	NAJ-4 SEC	SEVERAL PANEL BUTTONS ARE HARD TO OPERATE	REPLACE 5 BUTTONS
12/24/2012	MJ-6-A-10	BROKEN TOGGLE FOR DOOR	C/O REPLACE TOGGLE
12/26/2012	MJ-3-F-15	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
12/26/2012	MJ-5 POD D	BROKEN TOGGLE FOR DOOR	REPLACE TOGGLE
12/26/2012	MJ-1 BOOKING	BOND ROOM #1 PHONE NOT WORKING	REPLACE HANDSET ON INMATE SIDE
12/26/2012	NAJ-5	STAFF RESTROOM HEAT DET WON'T RESET	C/O BYPASS HD, RESET ALARM
1/2/2013	NAJ	TUBE STATION BROKEN	REPAIR STATION
1/2/2013	SAJ-1	ATTY. AREA FIRE ALARM	WATER LEAK, REMOVE SD RESET ALARM
1/2/2013	NAJ-3	SALLYPORT BY POD E, DIRTY SD	REPLACE SD
1/3/2013	NAJ-3	MINICOM DEF, #1 BUTTON IS STICKING	REPLACE IC BOX
1/3/2013	NAJ-2	MINICOM BOTH SIDES NOT WORKING	REPLACE
1/4/2013	NAJ-4	MASTER UNLOCK BUTTONS BROKEN	REPLACE BUTTONS
1/8/2013	MJ-3-B-11	DOOR SHOWS RED WHEN SECURE	NO PROBLEM FOUND
1/8/2013	MJ-3 SECURITY	TUBE STUCK	REMOVE TUBE, REPAIR STATION
1/8/2012	NAJ-2	PUBLIC SIDE VISITING, SD HANGING FROM CEILING	SECURE SD
1/9/2013	SAJ-3-D-10	SD NO ANSWER	REPLACE SD BASE
1/9/2013	NAJ-2	DEF SIDE IC NOT WORKING	REPLACE AND PROGRAM 2 DATA MODULES
1/10/2012	MJ-1 CLOTHING	TUBE STUCK	REMOVE TUBE, REPAIR STATION
1/10/2013	MJ-BASEMENT	TUNNEL CAMERA LOOKING AT TUNNEL SEC IS OUT	REPLACE CAMERA
1/10/2013	MJ-6	CONNECT DOOR INTERLOCK TO VISITING	INTERLOCKED WITH ALL POD DOORS
1/11/2013	MJ-6 POD B	SHOWER WATER LAMP IS OUT	REPLACE LAMP
1/11/2013	MJ-2 CENTRAL	OFFICER ENTRY OUTER UNLOCKS IN NEUTRAL	REPLACE DOOR SWITCH
1/11/2013	SAJ-4	MINICOM BOX HAS FEEDBACK	ADJUST BOX TEST OK
1/14/2013	MJ-5 DEF	MICROPHONE NOT WORKING	REPLACE MIC

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

1/14/2013	NAJ-2 POD B	DOOR SHOWS RED WHEN SECURE	LOCK IS STICKING REFER TO LOCKSMITH
1/14/2013	NAJ-3	INFIRMARY OFFICE DIRTY SD	REPLACE DIRTY SD
1/15/2013	MJ-5-D-11	DOOR SHOWS RED WHEN SECURE	REPLACE DOOR CARD, REFER TO LOCKSMITH
1/15/2013	MJ-3 VISITING	#1 PHONE INMATE SIDE IS BROKEN	REPLACE HANDSET
1/16/2013	MJ-5	DEF SIDE MICROPHONE NOT WORKING	REPAIR WIRING
1/16/2013	NAJ-1 COURT HLD	IC BOX NOT WORKING, #1 BUTTON	REPLACE BOX
1/17/2013	NAJ-2 POD E	DOOR WON'T SECURE	CHECK LOCK AND RELAY, REFER TO LOCKSMITH
1/18/2013	MJ-3-A-4	BROKEN TOGGLE FOR DOOR	REPLACE TOGGLE
1/21/2013	MJ-YARD	ELEV. #3 DOOR LOCK IS STICKING	CHECK, REFER TO LOCKSMITH
1/22/2013	SAJ-3-C-11	FIRE ALARM WON'T RESET	REPLACE DIRTY SD
1/22/2013	MJ-6-A-2	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/22/2013	MJ-4-F-2	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/22/2013	MJ-3-B	IC SPEAKER NOT WORKING	CHECK NO PROBLEM FOUND
1/22/2013	MJ-6 VISITING	CAMERA IS OUT	REPAIR VIDEO CONNECTION
1/23/2012	MJ-3-F-4	IC BUTTON NOT WORKING	REPLACE IC SWITCH, REPAIR BUTTON IN CELL
1/23/2013	MJ-6-B-12	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/23/2013	MJ-6-D-13	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/23/2013	MJ-6-F-15	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/24/2013	MJ-4-A-11	DOOR SOLID RED WHEN SECURE	REPLACE DOOR NO PROBLEM FOUND
1/24/2013	MJ-4-F-2	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/25/2013	MJ-4-D-9	BROKEN IC SWITCH	REPLACE TOGGLE
1/28/2013	MJ-3-C-11	DOOR FLASHES RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
1/28/2013	MJ-6-F	NOT ALL DOORS ARE INTERLOCKED	REPLACE CONNECTOR ON DOOR #2 CHECK OTHERS AND TEST
1/28/2013	SAJ-3-F	INTERCOM NOT WORKING	CHECK OK DAYROOM SPEAKER IS WEAK, NORMAL FOR SAJ
1/28/2013	MJ-6-F-14	IC BUTTON NOT WORKING	REPAIR BUTTON IN CELL
1/29/2013	NAJ-1 CENTRAL	FIRE ALARM MONITOR IS LOCKED UP	REPROGRAM MONITOR
1/29/2013	NAJ-1 CENTRAL	ROOF CAMERA IS STUCK CALLED UP	RESTART VIDEO SWITCHER
1/29/2013	MJ-1 LOBBY	BROKEN TOGGLE FOR BOND ROOM	REPLACE TOGGLE
1/30/2013	NAJ-5-C	HEAT DET IN RESTROOM KEEPS ALARMING	REPLACE HEAT DET AND BASE
1/30/2013	NAJ-5	SEVERAL CONSOLE BUTTONS ARE HARD TO OPERATE	REPLACE 2 BUTTONS
1/31/2013	SAJ-BASEMENT	CAMERA FOR ELEV. #3 VEST. IS OUT	REPLACE CAMERA
1/31/2013	MJ-4 ELEV.#1 VEST	SMOKE DET FAILED TEST	REPLACE SMOKE DET, REPEAT TEST OK
2/1/2013	SAJ-BASEMENT	TUNNEL SECURITY MONITOR IS OUT	REPLACE MONITOR
2/4/2013	NAJ-3	ABC SIDE IC NO AUDIO AT CONSOLE	REPLACE IC AMP
2/5/2013	MJ-2-CENTRAL	BROKEN TOGGLE FOR INF SIDE BRIEFING DOOR	REPLACE TOGGLE
2/6/2013	MJ-1	TUBE STUCK IN DIVERTER #15	REMOVE TUBE PURGE SYSTEM
2/7/2013	SAJ-BASEMENT	COURT HOLDING MONITOR BLACK ON VIDEO 1	REPAIR VIDEO FITTING AT SWITCHER
2/7/2012	SAJ-ATTY LOBBY	DORM BUTTON STICKS DOWN-UNLOCKED	REPLACE DOOR SWITCH

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

2/8/2013	MJ-3-E-9	BROKEN IC TOGGLE SWITCH	REPLACE TOGGLE
2/8/2013	SAJ-B-1	VEHICLE SALLY EXIT KEY SWITCH WIRE	REPAIR BROKEN WIRE
2/10/2013	MJ-5 EAST STAIR	DOOR 5006B UNLOCKS BY ITSELF	CHECK SWITCH, REPLACE DOOR CARD
2/10/2013	MJ-2-CENTRAL	ELEV #2 MONITOR IS OUT	REPLACE MONITOR
2/10/2013	MJ-4-E	FIRE ALARM WON'T RESET	BYPASS ZONE RESET ALARM
2/11/2013	MJ-4-E	FIRE ALARM ZONE BYPASSED	LOCATE AND REPLACE 2 SMOKE DET. SYSREM NORMAL
2/12/2013	NAJ-4 VISITING	2 BROKEN HANDSETS	REPLACE #4,6 ON INMATE SIDE
2/13/2013	NAJ-2	DEF MICROPHONE NOT WORKING	REPAIR WIRING AT MIC
2/13/2013	SAJ-3	DIRTY SMOKE DET IN SECURITY STATION	CLEAN SD
2/17/2013	MJ-2 SECURITY	ELEV. #2 IC SWITCH IS BROKEN	C/O REPLACE TOGGLE
2/17/2013	MJ-YARD	ELEV. #2 DOOR SWITCH IS BROKEN	REPLACE TOGGLE
2/18/2013	SAJ-LAUNDRY	EMTRY DOOR IC BUTTON IS STUCK	REPLACE IC BUTTON
2/18/2013	MJ-3-E-16	DOOR SWITCH IS BROKEN	REPLACE TOGGLE
2/19/2013	SAJ-1	BOND ROOM B HAS LOW VOLUME	REPAIR HANDSET
2/19/2013	SAJ-3	DAYROOM IC IS WEAK	CHECK, NO PROBLEM FOUND
2/19/2013	MJ-3-F-8	NO AUDIO IN CELL	CHECK NO PROBLEM FOUND
2/19/2013	NAJ-3	POD B SALLY PORT, DIRTY SMOKE DET	CLEAN SD
2/20/2013	NAJ-2 INFIRMARY	TUBE STATION BEEPING CONSTANTLY	REPLACE KEY PAD
2/21/2013	NAJ-3 SEC	DEF SIDE MINI COM NOT WORKING	REPAIR BOX AND TEST
2/21/2013	MJ-1 LOBBY	BROKEN TOGGLE FOR ELEV. VESTIBULE	REPLACE TOGGLE
2/25/2013	MJ ALL	TUBE SYSTEM IS DOWN	REMOVE PAPER BAGS FROM SYSTEM
2/25/2013	MJ-1	TRASH VESTIBULE INNER DOOR RED WHEN SEC	CHECK DOOR CARD REFER TO LOCKSMITH
2/25/2013	MJ-4-F-2	DOOR SHOWS RED WHEN SECURE	CHECK LOCK, DOOR CARD, SWITCH NO PROBLEM FOUND
2/26/2013	NAJ-3	EAST STAIRWELL VEST. DIRTY SMOKE DET	REPLACE DIRTY SD
2/26/2013	MJ-2 CENTRAL	2 BROKEN TOGGLE SWITCHES	REPLACE 2 TOGGLE SWITCHES
2/26/2013	MJ-3-F-13	BROKEN DOOR SWITCH	REPLACE TOGGLE
2/27/2013	MJ-5	DEF SIDE MICROPHONE NOT WORKING	C/O REPLACE MIC
2/28/2013	MJ-2 CENTRAL	BROKEN TOGGLE FOR VEHICLE SALLY ENTRY	REPLACE TOGGLE
2/28/2013	MJ-6-F-9	IC BUTTON IN CELL NOT WORKING	REPAIR IC BUTTON IN CELL
2/28/2013	MJ-4-F-2	DOOR FLASHES RED WHEN SECURE	CHECK AND REFER TO LOCKSMITH
2/28/2013	MJ-4	S. W. SALLYPORT DOOR RED WHEN SECURE	CHECK AND REFER TO LOCKSMITH
3/1/2013	MJ-3-B	BROKEN TOGGLE FOR GROUP UNLOCK	REPLACE TOGGLE
3/1/2013	MJ-1-BOOKING	BROKEN TOGGLE FOR MALE INTAKE	C/O REPLACE TOGGLE
3/4/2013	SAJ-3-G-2	TV CABLE DAMAGED INSIDE CONDUIT	REPLACE CABLE, INSTALL NEW FITTING AND COVER
3/4/2013	MJ-4-C-4	BROKEN TOGGLE FOR DOOR SWITCH	REPLACE DOOR SWITCH
3/4/2013	SAJ-2 SEC	24 CHANNEL VIDEO SWITCHER LOCKED UP	REPLACE WITH USED SWITCHER
3/5/2013	MJ-2 CENTRAL	BACK DOOR INNER UNLOCKS IN NEUTRAL	REPLACE SWITCH
3/5/2013	MJ-1 LOBBY	ELEV #4 DOOR SWITCH IS FALLING APART	REPLACE SWITCH
3/5/2013	MJ-1 LOBBY	OUTER RELEASE DOOR WON'T OPEN	REPLACE LEFT SIDE SWITCH

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

3/5/2013	MJ-2 CENTRAL	BROKEN TOGGLE FOT BACK DOOR INNER	C/O REPLACE TOGGLE
3/6/2013	MJ-2 CENTRAL	IC SWITCH FOR ELEV. #1 IS FALLING APART	REPLACE SWITCH
3/6/2013	MJ-4-E-16	DOOR RED WHEN SECURE	CHECK REFER TO LOCKSMITH
3/7/2013	MJ-BASEMENT	HOLDING CELLS SHOW RED WHEN SECURE	REPLACE DOOR CARD AND TIMMER
3/10/2013	MJ-3	ABC SIDE MICROPHONE NOT WORKING	C/O REPAIR MICROPHONE
3/11/2013	NAJ-4 SEC	UNLOCK BUTTONS HAS LONG DELAY	CHECK ALL UNLOCK BUTTONS NO PROBLEM FOUND
3/11/2013	NAJ-1 CENTRAL	MONITOR FOR 3RD FLOOR GYM IS OUT	REPLACE MONITOR
3/13/2013	SAJ-1 VISITING	REPLACE 3 HANDSETS	
3/13/2013	SAJ-2 CENTRAL	IC MIC NOT WORKING	CHECK MIC AND WIRING NO PROBLEM FOUND
3/13/2013	MJ-4-E-16	DOOR RED WHEN SECURE	CHANGE DOOR CARD, LS FOUND DEFECTIVE LOCK
3/14/2013	MJ-2 CENTRAL	ELEV #3 IC SWITCH NOT WORKING	REPAIR WIRING AT SWITCH
3/14/2013	MJ-6-D-12	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
3/14/2013	MJ-1-SEC	MINI COM BOX NOT WORKING	REPLACE BOX
3/15/2013	NAJ-5	DIRTY SMOKE DET SALLY BY B AND E	REPLACE 2 SMOKE DET
3/17/2013	NAJ-2	NO DOOR LOCK POWER	C/O CHECK POWER SUPPLY LOCATE SHORTED LOCK
3/18/2013	MJ-2 CENTRAL	DOOR SWITCH FOR BRIEFING STUCK UNLOCK	REPLACE DOOR SWITCH
3/18/2013	MJ-BASEMENT	MINI COM BOX HAS NOISE	REPLACE BOX
3/18/2013	MJ-1 CLOTHING	TUBE STUCK STATION 16	REMOVE TUBE REPAIR STATION
3/18/2013	MJ-3 SEC	ABC SIDE MONITOR IS OUT	REPLACE MONITOR
3/19/2013	MJ-1 LOBBY	TUBE STUCK STATION 19	REMOVE TUBE REPLACE LOADER MOTOR
3/20/2013	MJ-2 CENTRAL	DOOR SWITCH FOR ACCOUNTING UNLOCKS IN NEUT	REPLACE SWITCH
3/20/2013	MJ ALL	TUBE SYSTEM DIVERTER #15 BROKEN	REPLACE DIVERTER MOTOR
3/20/2013	MJ-3 SEC	BROKEN TOGGLE FOR ISO B	REPLACE TOGGLE
3/20/2013	NAJ-5	POD E AND ELEV #1 UNLOCK BUTTONS STUCK	REPLACE BUTTONS
3/21/2013	MJ-6-C-16	LOCK TIMMER IS TOO LONG	REPLACE DOOR CARD
3/25/2013	MJ-5 VISITING	#2 PHONE INMATE SIDE EXPOSED WIRES	REPLACE HANDSET
3/25/2013	MJ-2 CENTRAL	BACK DOOR INNER SWITCH WON'T UNLOCK	REPLACE DOOR SWITCH
3/25/2013	MJ-4	FIRE ALARM WON'T RESET WATER LEAK	HALL BEHIND GYM BYPASS WET SD
3/27/2013	MJ-2 CENTRAL	BACK DOOR INNER UNLOCKS IN NEUTRAL	REPLACE DOOR SWITCH
3/27/2013	MJ-2 INFIRMARY	TUBE STUCK IN STATION 11	REMOVE TUBE
3/29/2013	MJ-2 INFIRMARY	TUBE STUCK IN STATION 11	REMOVE TUBE REPLACE FUSE
3/29/2013	MJ-4	DEF SIDE MONITOR IS OUT	REPLACE MONITOR
3/29/2013	MJ-2, INFIRMARY	TUBE STUCK STATION 12	REMOVE TUBE, REPLACE FUSE
4/1/2013	MJ-4-E-16	DOOR WON'T UNLOCK, KEY OR CONSOLE	CHECK, NO PROBLEM FOUND, PAPER JAM
4/2/2013	NAJ-5	METAL DETECTOR NOT FUNCTIONING CORRECTLY	REPAIR X-MITTER BOARD, RECALIBRATE
4/3/2013	MJ-TUNNEL	CAMERA VIEWING TUNNEL SEC IS OUT	REPLACE CAMERA
4/3/2013	MJ-2 CENTRAL	BROKEN TOGGLE FOR BASEMENT DOOR	REPLACE DOOR SWITCH
4/3/2013	NAJ-1 CENTRAL	CAMERA FOR ELEV. #3 IS OUT	C/O REPLACE CAMERA POWER OUTAGE, UPS FAILURE
4/5/2013	MJ-5-A-8	IC SWITCH WON'T WORK	C/O REPLACE IC SWITCH
4/8/2013	MJ-2 CENTRAL	DOOR SW FOR INFIRMARY-BRIEFING WON'T LOCK	C/O REPLACE DOOR SWITCH

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

4/8/2013	SAJ-1 VISITING	BROKEN HANDSET S. SIDE INMATE	REPLACE HANDSET
4/8/2013	MJ-3-E-5	IC WON'T CALL IN	REPLACE IC SWITCH IN CONSOLE
4/9/2013	MJ-2 CENTRAL	DOOR SW FOR ADMIN-ELEV #4 UNLOCKS IN NEU	REPLACE DOOR SWITCH
4/9/2013	SAJ-1 VISITING	INMATE DOOR S. SIDE SHOWS UNSECURE	REPLACE GREEN LAMP AT DOOR SWITCH
4/9/2013	MJ-4-DEF SIDE	MICROPHONE NOT WORKING	REPLACE MICROPHONE
4/9/2013	SAJ-3-G-3	TV CABLE FITTING IS LOOSE	REPLACE FITTING AND CABLE
4/9/2013	MJ-2 CENTRAL	BROKEN TOGGLE FOR ADMIN DOOR	REPLACE TOGGLE
4/10/2013	MJ-BASEMENT	TUNNEL SECURITY MONITOR IS OUT	REPLACE MONITOR
4/14/2013	MJ-1-LOBBY	OUTER RELEASE DOOR WON'T SECURE	C/O REPLACE DOOR SWITCH
4/17/2013	NAJ-5 VISITING	PHONE #10 IS NOT WORKING	REPAIR PHONE ON INMATE SIDE
4/19/2013	MJ-4-D-2	BROKEN IC SWITCH	REPLACE TOGGLE
4/19/2013	MJ-5-F-10	DOOR SHOWS RED WHRN SECURE	CHECK, LOCK IS BROKEN REFER TO LOCKSMITH
4/19/2013	MJ-4-F-4	WON'T SHOW GREEN WHEN SECURE	REPLACE GREEN LAMP AT DOOR SWITCH
4/19/2013	MJ-5-A-6	CEILING SPEAKER IS LOOSE	SECURE SPEAKER
4/22/2013	SAJ-2-SECURITY	MONITOR IS OUT	REPLACE B-W MONITOR
4/22/2013	MJ-2 CENTRAL	DVR CHANNEL 27 BLACK SCREEN	REBOOT DVR, CHECK OK
4/24/2013	MJ-1-BOOKING	BOND ROOM #2 HANDSET EXPOSED WIRES	REPAIR INMATE SIDE HANDSET
4/25/2013	MJ-2 CENTRAL	LOADING DOCK INNER DOOR WON'T UNLOCK	REPLACE DOOR SWITCH
4/25/2013	NAJ-4	A-B LOWER FIRE DOOR RED WHEN SECURE	CHECK NO PROBLEM FOUND REFER TO LOCKSMITH
4/26/2013	MJ-2 CENTRAL	CAMERA FOR VEHICLE SALLYPORT IS DISTORTED	REPAIR VIDEO FITTING
4/29/2013	SAJ-3	INMATES CAN'T HEAR IC	CHECK NO PROBLEM FOUND
4/30/2013	MJ-3-SECURITY	DOOR SWITCH FOR SEC DOOR BROKEN	REPLACE TOGGLE
4/30/2013	MJ-3 GYM	CAMERA IS OUT	REPLACE CAMERA
5/1/2013	SAJ-M STREET	BROKEN TOGGLE FOR PUBLIC VISITING	REPLACE TOGGLE
5/3/2013	MJ-4 ELECT RM	FIRE ALARM PANEL WET FROM WATER LEAK	SHUT DOWN PANEL
5/6/2013	MJ-4 ELECT RM	RESTART FIRE PANEL TEST ZONES OK	
5/6/2013	NAJ-4	HALL BY ELECT RM SD NO ANSWER	REPLACE SD BASE
5/6/2013	MJ-3 FF HALL	MONITOR IS OUT	REPAIE VIDEO FITTING
5/6/2013	MJ-6	ELEV. #3 CAMERA IS OUT	REPLACE CAMERA
5/7/2013	MJ-2	CAMERA FOR INF BRIEFING EXIT IS OUT	REPLACE CAMERA
5/7/2013	MJ-2 CENTRAL	ELEV. #4 VEST DOOR WON'T SECURE	REPLACE DOOR SWITCH
5/7/2013	MJ-4-A-3	BROKEN TOGGLE FOR DOOR	REPLACE TOGGLE
5/8/2013	NAJ-4	DEF SIDE MIC NOT WORKING	REPAIR WIRING AT MIC
5/12/2013	MJ-1 LOBBY	RELEASE DOOR INNER UNLOCKS BY ITSELF	REPLACE DOOR SWITCH
5/13/2013	SAJ-3 SEC	VOLUME CONTROL ON CONSOLE WON'T WORK	REPLACE VOLUME CONTROL
5/13/2013	SAJ CENTRAL	MINI COM BOX NOT WORKING WELL	REPLACE IC BOX
5/13/2013	MJ-3-D	CELL CHASE 3-4 SMOKE DET FAILED TEST	REPLACE SD AND RETEST
5/14/2013	MJ-5-A	CELL CHASE13-14 SMOKE DET FAILED TEST	REPLACE SD AND RETEST
5/15/2013	MJ-5-E-7	DOOR WON'T UNLOCK, KEY OR CONSOLE	REPLACE DOOR CARD, REFER TO LOCKSMITH
5/16/2013	SAJ-1 VISITING	EXPOSED WIRES SOUTH SIDE INMATE SIDE	REPAIR WIRING, CHECK ALL.

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

5/16/2013	MJ-2-A-4	CABLE TV FITTING ON WALL IS BAD	REPLACE FITTING
5/18/2013	MJ-6	DEF SIDE MIC NOT WORKING	C/O REPAIR MIC
5/20/2013	SAJ-2-CENTRAL	MINI COM BOX IS SQUEAKING WITH FEEDBACK	ADJUST BOX
5/20/2013	MJ-3	DEF SIDE MIC NOT WORKING	REPAIR WIRING AT MIC
2/20/2013	MJ-6-C-7	DOOR SHOWS RED WHEN SECURE	CHECK, NO PROBLEM FOUNG
5/21/2013	MJ-4-FF-B	BROKEN TOGGLE	REPLACE TOGGLE
5/21/2013	SAJ-2-CENTRAL	MONITOR FOR MEDICAL HALL GOES IN AND OUT	REPLACE VIDEO FITTING AT MONITOR
5/23/2013	SAJ-2-CENTRAL	MONITOR FOR COURT HOLDING IS GOING OUT	REPLACE MONITOR
5/24/2013	MJ-5-C-12	DOOR WON'T UNLOCK, KEY OR CONSOLE	CHECK LOCK BROKEN REFER TO LOCKSMITH
5/24/2013	MJ-3-B-13	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
5/24/2013	MJ-3-F-10	BROKEN TOGGLE FOR IC	REPLACE TOGGLE
5/24/2013	MJ-5-F	POD DOOR BROKEN TOGGLE	REPLACE TOGGLE
5/24/2013	MJ-6, ISO B	BROKEN TOGGLE	REPLACE TOGGLE
5/28/2013	NAJ-2	DEF SIDE MIC NOT WORKING	REPLACE MICROPHONE
5/28/2013	MJ-BASEMENT	ELEV. #3 VEST DOOR UNLOCKS BY ITSELF	REPLACE DOOR SWITCH AND DOOR CARD
5/28/2013	MJ-1-BOOKING	ENROUTER VESTIBULE CAMERA IS OUT	REPLACE CAMERA
5/28/2013	NAJ-3	MINI COM BOX NOT CLEAR	REPLACE ONE BOX, ADJUST OTHER
5/28/2013	MJ-3	TUBE STUCK	REMOVE TUBE, REPAIR STATION
5/29/2013	MJ-5 VISITING	#7, 9 PHONES NOT WORKING	REPLACE #7 CHECK ALL OTHERS
5/29/2013	MJ-5-A-8	SCREWS ARE MISSING FROM IC SPEAKER	REPLACE SCREWS
5/29/2013	SAJ-ATTY LOBBY	VIDEO MONITOR IS DISTORTED	REPLACE MONITOR
5/29/2013	SAJ-COURT HOLD	CAMERA FOR COURT EXIT IS OUT	REPLACE CAMERA
5/30/2013	SAJ-VISITING	2 PHONES S. SIDE INMATE EXPOSED WIRES	REPAIR WIRING
6/3/2013	NAJ 3 SEC	TUBE STUCK	REMOVE STUCK TUBES
6/4/2013	NAJ-4	DIRTY SMOKE DET SALLTPORT BY POD E	REPLACE SMOKE DET
6/4/2013	NAJ-3 SEC	TUBE STUCK	REMOVE TUBE, RESET SYSTEM
6/4/2013	MJ-4-C	IC SPEAKER BROKEN FROM WALL	REPLACE WITH REPAIRED BRACKET
6/6/2013	MJ-5-D	IC SPEAKER BROKEN FROM WALL	REPLACE WITH REPAIRED BRACKET
6/6/2013	NAJ 3-B	HEAT DET TROUBLE, WRONG ANSWER	WATER DAMAGE, REPLACE HEAT DET AND BASE
6/7/2013	NAJ-5 POD C	DOOR SHOWS RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
6/7/2013	MJ-5, E-7	DOOR WON'T UNLOCK, CONSOLE OR KEY	REPLACE DOOR CARD REFER TO LOCKSMITH
6/10/2013	SAJ-3, D-5	SMOKE DET NO ANSWER	REPLACE SD AND BASE
6/11/2013	NAJ-3	ABC SIDE IC AMP NOT WORKING PROPERLY	REPLACE IC AMP
6/12/2013	MJ-6	ABC SIDE MIC IS INTERMITENT	REPLACE MIC
6/12/2013	MJ-2 CENTRAL	DVR DRIVE FAILED	6/13 INSTALL REPAIRED DVR
6/13/2013	NAJ-2	ABC SIDE MINI COM IS NOT WORKING	REPLACE CORD, TEST OK
6/14/2013	MJ-5, F-10	DOOR SHOWS RED WHEN SECURE	BROKEN LOCK, REFER TO LOCKSMITH
6/14/2013	MJ-5, F-13	DOOR SHOWS RED WHEN SECURE	BROKEN LOCK, REFER TO LOCKSMITH
6/14/2013	MJ-4, B-3	BROKEN TOGGLE	REPLACE TOGGLE
6/15/2013	ALL	SCHEDULED POWER OUTAGE	C/O RESET SEVERAL SYSTEMS

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

6/17/2013	SAJ-ALL	MINICOM NOT WORKING	REPLACE POWER SUPPLY
6/17/2013	MJ-4	SEC DOOR TOGGLE DEF SIDE BROKEN	REPLACE TOGGLE
6/17/2013	NAJ	TUBE SYSTEM IS DOWN	RESET ALL STATIONS
6/17/2013	MJ-3, C-11	DOOR SHOWS RED WHEN SECURE	CHECK, NO PROBLEM FOUND
6/17/2013	SAJ-4	VIDEO SWITCHER NOT WORKING	REPLACE VIDEO SWITCHER
6/18/2013	NAJ-2 VISITING	PUBLIC SIDE #6 PHONE EXPOSED WIRES	REPLACE HANDSET
6/18/2013	MJ-5	GYM BACK DOOR UNLOCKS BY ITSELF	REPLACE DOOR CARD
6/18/2013	SAJ-2 SECURITY	ONE SMALL MONITOR IS OUT	REPLACE MONITOR
6/19/2013	MJ-2	INFIRMARY SIDE BRIEFING DOOR WON'T UNLOCK	REPLACE DOOR CARD AND SWITCH, REFER TO LOCKSMITH
6/19/2013	MJ ELEV #4	CAMERA GOES OUT SOMETIMES	REPLACE CAMERA
6/19/2013	SAJ-3, G-3	CHECK TV CABLE FITTING	CHECK OK
6/19/2013	MJ-3, B-11	NO KEY OR CONSOLE OPERATION	C/O CHECK, NO PROBLEM FOUND
6/20/2013	MJ-3	METAL DET ACTIVATING FOR NO REASON	ADJUST AND CHECK
6/20/2013	MJ-3, FF-8	FLASHING RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
6/20/2013	MJ-1	DOOR 1092, NO KEY OPERATION	CHECK, REFER TO LOCKSMITH
6/24/2013	MJ-3, B-11	NO KEY OR CONSOLE OPERATION	FUSE IS BLOWN, REPLACE AND REFER TO LOCKSMITH
6/24/2013	SAJ-2 CENTRAL	VIDEO SWITCHER STUCK ON CAM #48	REPLACE SHORTED IC SWITCH
6/24/2013	MJ-3, B-15	IC WON'T CALL IN	REPLACE IC SWITCH AND TEST
6/24/2013	MJ-1	VEHICLE ENTRY, NEW MOTOR CONTROLLER	C/O CONNECT WIRES TO NEW CONTROLLER
6/25/2013	MJ-2 CENTRAL	CENTRAL OUTER DOOR SWITCH STICKS UNLOCK	REPLACE DOOR SWITCH
6/26/2013	NAJ-CENTRAL	MONITOR FOR 2ND FLOOR IS OUT	REPAIR MONITOR
6/28/2013	MJ-4, D-3	DOOR KEEPS UNLOCKING	REPLACE DOOR CARD AND TEST OK
6/28/2013	MJ-4, F-10	DOOR FLASHING RED WHEN SECURE	CHECK, REFER TO LOCKSMITH
6/28/2013	MJ-4, A, 1-2	FIRE ALARM WON'T RESET	WATER LEAK, BYPASS SD, REPLACE SD
6/29/2013	MJ-3	BROKEN TOGGLE FOR ELEV. #1 DOOR	C/O REPLACE 2 TOGGLES FOR WATER CONTROL
7/1/2013	SAJ-4	SOME CAMERAS ARE NOT CALLING UP	CHECK ALL CAMERAS OK
7/1/2013	SAJ-2 CENTRAL	ELEV. MIC IS NOT WORKING	REPAIR WIRING AT MIC
7/1/2013	MJ-6, A-16	IC WON'T CALL IN	REPAIR IC BUTTON IN CELL
7/3/2013	NAJ-5	DEF MONITOR IS BLUE SCREEN	SET MONITOR TO VIDEO 1
7/3/2013	MJ-5 POD B	DIRTY SMOKE DET	REPLACE SMOKE DET
7/4/2013	MJ-1 BOOKING	MALE ENTRY DOOR SWITCH NOT WORKING	C/O REPLACE DOOR SWITCH
7/5/2013	NAJ-2	MINICOM NOT WORKING	CORD UNPLUGGED, REPLACE TEST OK
7/5/2013	MJ-6	ABC SIDE CAM #4 NOT WORKING	SECURE VIDEO FITTING
7/8/2013	SAJ-4, E-9	INMATES CAN'T HEAR INTERCOM	REMOVE DEBRIS FROM INMATE SPEAKER
7/9/2013	MJ-2 SEC	TUBE STUCK IN STATION #11	REMOVE TUBE TEST STATION
7/9/2013	MJ-3	DEF SIDE MONITOR IS OUT	REPLACE MONITOR
7/10/2013	NAJ ALL	MUSIC RADIO IS NOT WORKING	REPLACE FUSE IN PRIMARY AMP
7/10/2013	MJ-5	SEC DOOR TOGGLE SWITCH IS STICKING	REPLACE BOTH TOGGLE SWITCHES
7/10/2013	MJ-1 CLOTHING	TOGGLE FOR DRESS IN TO ELEV #3 WORN OUT	REPLACE TOGGLE

FRESNO COUNTY JAIL SECURITY SYSTEM SERVICE HISTORY JUNE 2012-JULY 2013

7/10/2013	SAJ-1 M ST	NOISE IN MINICOM BOX	FANS ARE CAUSING THE PROBLEM
7/10/2013	MJ-6	ABC SIDE CAM #4 NOT WORKING	REPAIR VIDEO FITTING
7/13/2013	MJ-1 BOOKING	MALE ENTRY DOOR SWITCH NOT WORKING	C/O REPLACE DOOR SWITCH
7/15/2013	NAJ BASEMENT	HOLDING CELL #3 LOCK IS STICKING	CHECK REFER TO LOCKSMITH
7/15/2013	MJ-3 POD D	DOOR SWITCH UNLOCKS IN NEUTRAL	REPLACE DOOR SWITCH
7/15/2013	MJ-3	ISO MONITOR B IS NOT WORKING	REPAIR MONITOR
7/16/2013	MJ-2 CENTRAL	BACK DOOR INNER SWITCH WON'T UNLOCK	REPLACE DOOR SWITCH
7/16/2013	NAJ-4	TUBE STUCK IN STATION #42	REMOVE TUBE TEST STATION
7/16/2013	SAJ-BASEMENT	LAUNDRY IC BUTTON NOT WORKING	REPAIR BUTTON
7/16/2013	MJ-1 BOOKING	METAL DET KEEPS GOING OFF	CLEAN AND ADJUST
7/16/2013	NAJ-3	SALLYPORT BY VISITING, DIRTY SMOKE DET	REPLACE SMOKE DET
7/17/2013	MJ-2 SECURITY	ONE SMALL MONITOR IS OUT	REPLACE WITH LCD MONITOR RACK
7/22/2013	NAJ-2	MASTER UNLOCK BUTTON IS BROKEN	REPLACE BOTH MASTER UNLOCK BUTTONS
7/22/2013	NAJ-4	VISITING DOOR BUTTONS NOT WORKING	REPLACE BUTTONS
7/23/2013	MJ-2 CENTRAL	ACCOUNTING DOOR SWITCH UNLOCKS IN NEUTRAL	REPLACE DOOR SWITCH
7/23/2013	MJ-1 LOBBY	MAIN MONITOR IS OUT	REPLACE MONITOR
7/23/2013	MJ-5	FF MONITOR B IS VERY DARK	REPLACE MONITOR
7/24/2013	SAJ-3 HALL D,E	CAMERA IS OUT	REPLACE CAMERA
7/26/2013	MJ-2 SEC	TUBE STUCK IN STATION #11	REMOVE TUBE, REPLACE FUSE, TEST
7/26/2013	SAJ-3	2 MONITORS ARE OUT	REPAIR MONITORS
7/26/2013	NAJ-2 CLASSRM	SMOKE DET B IS DIRTY	REPLACE SMOKE DET
7/26/2013	NAJ-1 CENTRAL	IC BOX IS NOT WORKING	REPLACE WATER DAMAGED IC BOX
7/29/2013	NAJ-4	BOTH IC BOXES ARE NOT WORKING	REPLACE BOTH
7/30/2013	NAJ-2 SEC	SMOKE NOTICED IN SEC	NO PROBLEM FOUND
7/30/2013	NAJ-1 CENTRAL	CAMERA FOR 2ND FLOOR GYM DISTORTED	REPAIR VIDEO FITTING ON 2ND FLOOR
7/31/2013	NAJ-3	IC RESET BUTTONS ARE BROKEN	REPLACE BUTTONS